

State Water Resources Control Board

September 28, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7018 0680 0000 1017 5932

Ms. Susan Stewart
Tank Program Manager
Beale Air Force Base
6425 B Street, Building 25390
Beale Air Force Base, California 95903
susan.stewart.7@us.af.mil

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS
LOCATED AT BEALE AIR FORCE BASE AAFES CAPEHART SHOPPETTE,
4903 CAMP BEALE ROAD, HW SITE #111, B4793, BEALE AIR FORCE BASE**

Dear Ms. Stewart:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on September 26, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Monitoring Plan – The monitoring plan must be updated to include correct line leak detector and sensor model numbers.	All	September 26, 2018	Ongoing	H&SC 25286(a); 23 CCR 2632(d)(1), 2711(a)(9)
2	Failure to Meet Designated Operator (DO) Inspection Requirements – Between October 2017 and March 2018, the DO monthly inspection reports were incomplete because they were missing page 2. Additionally, an alarm that occurred on January 23, 2018, was not documented on the January 24, 2018 DO inspection report since page 2 was missing.	All	October 1, 2017	March 31, 2018	23 CCR 2715(c)

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Yuba County Environmental Health Department within sixty (60) days from the date of this letter. Have your DO make specific notations in the next monthly DO report indicating the ongoing violations have been corrected. The monthly DO report and any associated photos must be submitted as proof of compliance. Please ensure the street address on all facility documents, such as test records, lists the same address as the facility information in CERS.

Please send all compliance documentation to the following:

State Water Board

Ms. Rebecca Green
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
rebecca.green@waterboards.ca.gov

Local CUPA

Mr. Clark Allen Pickell
Director Environmental Health
Yuba County Environmental
Health Department
915 8th Street, Suite 123
Marysville, California 95901
cpickell@co.yuba.ca.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: (via email only)

Mr. Gary Cantwell
Program Supervisor
Yuba County Environmental
Health Department
gcantwell@co.yuba.ca.us

Mr. Clark Allen Pickell
Director Environmental Health
Registered Environmental Health Specialist
Yuba County Environmental
Health Department
cpickell@co.yuba.ca.us

Ms. Gwendolyn Vergara
Chief of Environmental Element
Beale Air Force Base
gwendolyn.vergara.1@us.af.mil